



EFFECTIS ERA AVRASYA TEST ve BELGELENDİRME AŞ
Dilovası OSB Mahallesi Fırat Caddesi No: 18
Dilovası, Kocaeli / TÜRKİYE
www.effectis.com

DECLARATION OF TEST RESULTS

No: EEA – 2100 – 0113

The fire resistance tests were carried out for the product as described below at Efectis Era Avrasya Test Laboratory on 22.12.2021 in accordance with the test standard:

EN 1634-1:2014+A1:2018

Steel Non-Insulated Roller Shutter – FIRUS 240

FIRE RESISTANCE CLASSIFICATION	
Direction: Barrel and supporting components on the fire side	E240
Direction: Barrel and supporting components away from the fire side	E240

Placed on the market by: FIRUS YANGIN OTOMASYON GÜVENLİK SİSTEMLERİ MÜHENDİSLİK A.Ş.
Maltepe Mah. Fazılpaşa Çıkma Sok. No:6/1 Zeytinburnu,
İstanbul/TURKEY

Manufactured by: FIRUS YANGIN OTOMASYON GÜVENLİK SİSTEMLERİ MÜHENDİSLİK A.Ş.
Maltepe Mah. Fazılpaşa Çıkma Sok. No:6/1 Zeytinburnu,
İstanbul/TURKEY

Ali BAYRAKTAR
e-signed
Laboratory Manager
23.12.2021

This document is a declaration of test results and does not represent any type of approval or certification of the product. All details related to product specifications and field of applications are described in the report No: EEA-21-175.

